

20699

台灣 基隆市

七堵區百三街105之4

金華電子股份有限公司

JENB ZHENG



JENB ZHENG  
 KING WAHOO ELECTRONICS CO LTD  
 105-4 BRI 3RD ST  
 KEELUNG TAIWAN

Date: 2019/03/30  
 Subscriber: 100033482  
 PartySite: 182380  
 File No: E302100  
 Project No: 4788934221  
 PD No: 19016981  
 Type: R  
 PO Number:

Subject: **Procedure And/Or Report Material**

The following material resulting from the investigation under the above numbers is enclosed.

**Issue**

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
	1		<b>Appendix</b>	
2010/01/27	1	7	Revised Description Page(s) 1,11	2019/03/26
2010/01/27	1	7	<b>New</b> Figure(s) 3	2019/03/26
2010/01/27	1	7	<b>New</b> Test Record 5	2019/03/26

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://ul.com/aboutul/locations>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above.

This material is provided on behalf of UL LLC(UL) or any authorized licensee of UL.

NBK File

FUSES, SUPPLEMENTAL (JDYX, JDYX7)  
COMPONENT - FUSES, SUPPLEMENTAL (JDYX2, JDYX3, JDYX8, JDYX9)

TABLE A - SAMPLE SELECTION GUIDE &amp; INDEX TO TESTING

Sample Group	Model	Report Date	Category	Construction Number	Rating (Current/Voltage)	Interrupting Ability Ratings (Current/ Voltage)	Adhesive Used?	Additional Info	Test Program Code - Annually	Test Program Code - Biennially
48	HV610, HV620, HV630, HV640, HV650	2013-09-09	Supplemental fuses: filled-tube	14A	0.1-12A /1000Vdc	10000A / 1000Vdc	No	-	B	-
					0.1-12A /600Vdc	10000A / 600Vdc	No	-	B	-
					0.1-30A /660Vac	1000A / 660Vac	No	-	B	-
					0.1-30A /660Vdc	1000A / 660Vdc	No	-	B	-
					0.1-50A /250Vac	1000A / 250Vac	No	-	B	-
49	MFC	2011-12-29	Supplemental micro fuses	8L	0.125-0.125A /125Vac	1500A / 125Vac	No	-	A	-
					0.125-0.125A /125Vac	1500A / 125Vac	No	-	A	-
					0.125-0.125A /250Vac	4000A / 250Vac	No	-	A	-
					0.125-0.125A /250Vac	1500A / 250Vac	No	-	A	-
					0.125-0.125A /250Vac	1500A / 250Vac	No	-	A	-
					0.125-0.125A /250Vdc	4000A / 250Vdc	No	-	A	-
50	3TS	2013-08-29	Supplemental micro fuses: pigtail leads, filled-tube, cartridge enclosed	9B	0.2-6.3A /125Vac	35A / 125Vac	No	-	B	-
					0.2-6.3A /250Vac	35A / 250Vac	No	-	B	-
					0.2-6.3A /250Vac	50A / 250Vac	No	-	B	-
					0.2-6.3A /250Vac	100A / 250Vac	No	-	B	-
					0.2-6.3A /250Vac	150A / 250Vac	No	-	B	-

FUSES, SUPPLEMENTAL (JDYX, JDYX7)  
COMPONENT - FUSES, SUPPLEMENTAL (JDYX2, JDYX3, JDYX8, JDYX9)

TABLE A - SAMPLE SELECTION GUIDE &amp; INDEX TO TESTING

Sample Group	Model	Report Date	Category	Construction Number	Rating (Current/Voltage)	Interrupting Ability Ratings (Current/ Voltage)	Adhesive Used?	Additional Info	Test Program Code - Annually	Test Program Code - Biennially
52	5TS Alternate Series name S510 or S502	2019-02-22	Supplemental fuses: pigtail leads, filled-tube, cartridge enclosed	16	0.2-10A /125Vac	1500A / 125Vac	No	-	B	-
					0.2-10A /250Vac	1500A / 250Vac	No	-	B	-
					0.2-20A /125Vac	1000A / 125Vac	No	-	B	-
					0.2-20A /250Vac	1000A / 250Vac	No	-	B	-
					0.2-20A /400Vac	300A / 400Vac	No	-	B	-
					0.2-20A /450Vac	200A / 450Vac	No	-	B	-